

Aaron Guckian
Chairman

Janine L. Burke
Executive Director



Scott Avedisian
Mayor

Warwick Sewer Authority
125 Arthur W. Devine Boulevard
Warwick, RI 02886
Voice: (401) 739-4949 • Fax: (401) 739-1414


IN THE EVENT OF AN ALARM

The Alarm on your EONE grinder pump indicates that the water level in the unit is too high. This alarm is the warning that the unit may back up. It is suggested to stop the use of all water until the problem is identified and the pump is serviced.

If an alarm condition does not clear itself after 15 minutes, please call for service.
Repetitive intermittent alarms should be reported to service as this signal may indicate that a part could be wearing out or not working properly.

Silencing an Alarm

The alarm may be silenced by pushing the silence button located on the bottom of the alarm panel. Be advised, the light will stay lit.



KEEPING WATER USE TO A MINIMUM

Listed below are a few helpful hints to keep water use to a minimum while waiting for service:

1. Flush only when necessary.
2. If you need to run the tub or shower, put a stopper in the drain to keep the water from going down the drain.
3. Do not run appliances that require water, such as washing machines or dishwashers.
4. Use sinks sparingly.

If you experience a problem with your grinder pump, you may contact the E/One pump manufacturer's representative, F.R. Mahony & Associates, Inc., at (800) 791-6132 or (508) 765-0051.